

Fire Test Report

ANSI/API Standard 607, 7th Edition, 2016


ISO 10497: 2010

API Standard 6FA, Fifth Edition, May 2020

Performed for

MOGAS Industries, Inc.

www.mogas.com



8 inch Class 1500 T-Series
Valve Code: T-Series

Project Number: 220228
Test Date: August 5, 2020

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road
North Yarmouth, ME 04097 USA
(207) 829-5359

info@yarmouthresearch.com
www.yarmouthresearch.com

Yarmouth Research and Technology, LLC

Customer: MOGAS Industries, Inc.	Date: 8/5/2020
Specifications: ANSI/API Standard 607, Seventh Edition, 2016 ISO 10497: 2010	
API Standard 6FA, Fifth Edition, May 2020	
Product Description: 8" 1500# T-Series	
Project Number: 220228	

Equipment Confirmed to be in Calibration to NIST Standards: Yes
--

Burn and Cool Down Test

Burn Start Time:	8:14:00	
Average Pressure During Burn:	2809	psig
Seat Leak Rate During Burn:	0	ml/min
Allowable Seat Leak Rate:	3200	ml/min
External Leak Rate During Burn/Cool Down:	0.4	ml/min
Allowable External Leak Rate:	800	ml/min
Amount of Time of Avg. Cal. Blocks > 650 deg. C:	21.5	minutes
Were Test Conditions Within Compliance?	Yes	
Were the Valve Leakages Below the Allowables?	Yes	

Operational Test

Average Pressure During Test:	2817	psig
External Leak Rate After Operating:	6.4	ml/min
API 607 7th Edition Allowable External Leak Rate:	200	ml/min
API 6FA 5th Edition Allowable External Leak Rate:	1600	ml/min
Was the Leakage Below the Allowables?	Yes	
Does Valve Pass or Fail the Test Standards?	PASS	

Certified by



Matthew J. Wasielewski, PE
President and Manager
Yarmouth Research and Technology, LLC

