

Fire Test Report

ANSI/API Standard 607, 7th Edition, 2016

ISO 10497: 2010

API Standard 6FA, Third Edition, April 1999

Performed for

MOGAS Industries, Inc.

www.mogas.com



2 inch Class 2500 C-Series Floating Ball Valve
Valve Code: 2" 2500 CA-1AS

Project Number: 217143

Test Date: May 16, 2018



Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road
North Yarmouth, ME 04097 USA
(207) 829-5359

info@yarmouthresearch.com

www.yarmouthresearch.com

Yarmouth Research and Technology, LLC

Customer: MOGAS Industries, Inc.

Date: 5/16/2018

Specifications: ANSI/API Standard 607, Seventh Edition, 2016 ISO 10497: 2010

API Standard 6FA, Third Edition, April 1999 (R2008)

Product Description: 2" Class 2500 C-Series Floating Ball Valve

Valve Code: 2" 2500 CA-1AS

Project Number: 217143

Equipment Confirmed to be in Calibration to NIST Standards: Yes

Burn and Cool Down Test

Burn Start Time:	9:18:00	
Average Pressure During Burn:	4629	psig
Seat Leak Rate During Burn:	0	ml/min
Allowable Seat Leak Rate:	800	ml/min
External Leak Rate During Burn/Cool Down:	2.8	ml/min
Allowable External Leak Rate:	200	ml/min
Amount of Time of Avg. Cal. Blocks > 650 deg. C:	21.5	minutes
Were Test Conditions Within Compliance?	Yes	
Were the Valve Leakages Below the Allowables?	Yes	

Operational Test

Average Pressure During Test:	4542	psig
External Leak Rate After Operating:	0	ml/min
API 607 7th Edition Allowable External Leak Rate:	50	ml/min
API 6FA 3rd Edition Allowable External Leak Rate:	400	ml/min
Was the Leakage Below the Allowables?	Yes	
Does Valve Pass or Fail the Test Standards?	PASS	

Certified by



Matthew J. Wasielewski, PE

President and Manager

Yarmouth Research and Technology, LLC

